

Dr. Thomas Tramaglini  
Superintendent



Anthony Lepore  
Supervisor of Facilities

Vincent A. Gonnella  
Business Administrator  
Board Secretary

**Kenilworth Public Schools**  
**Office of Facilities Management**  
www.kenilworthschools.com  
401 Monroe Avenue  
Kenilworth, New Jersey 07033  
908-931-9696

### **Drinking Water Sample Results - Website**

On Saturday May 14, 2016 and Thursday May 26, 2016 the Kenilworth Public School District conducted lead in drinking water sampling. The lead in drinking water sampling was conducted in accordance with the New Jersey Schools Lead in Drinking Water Regulations; N.J.A.C. 6A:26-1.2;12.4 and the USEPA "3 T's for Reducing Lead in Drinking Water in Schools".

A total of one-hundred forty-six (146) drinking water samples were collected from all drinking water outlets to which a student or staff member has or may have access to in all Kenilworth Public School facilities. Analytical results for all but one sample were below the action level of 15ppb. Proper remedial actions were taken at the one sampling location that tested above the action level.

Name of NJ Certified Laboratory who performed the analytical testing and certification number:

Name: ESC Lab Sciences      Certification Number: TN002

The results are listed in the following table.

<b>School</b>	<b>Sample Name</b>	<b>Location</b>	<b>Results (ppb)</b>
<b>Harding</b>	<b>Main Draw Meter Room</b>	<b>Meter Room</b>	<b>57.1</b>
Harding	Nurse Sink	Nurses Office	2.3
Harding	Adjacent Faculty Bathroom 1	Hallway	1.4
Harding	Fountain A1-1	A1 Corridor	2.5
Harding	Fountain A1-2	A1 Corridor	2.3
Harding	Room 121 Fountain	Room 121	ND
Harding	Adjacent Faculty Bathroom 2	Hallway	ND
Harding	Room 137 Fountain	Room 137	ND
Harding	Cafeteria 2	Cafeteria	ND
Harding	Room 167 Fountain	Room 167	ND
Harding	Room 170 Fountain	Room 170	1.2
Harding	Corridor D1 Fountain	Corridor D1	1.1
Harding	Room 169 Fountain	Room 169	1.6

Harding	Room 164 Fountain	Room 164	ND
Harding	Room 168 Fountain	Room 168	ND
Harding	Room 156 Fountain	Room 156	2.6
Harding	Adjacent Room 148-1	Corridor C1	1.1
Harding	Room 160 Fountain	Room 160	1.4
Harding	Room 154 Fountain	Room 154	4.4
Harding	Adjacent Room 143-1	Corridor A1	4.5
Harding	Adjacent Room 148-2	Corridor C1	ND
Harding	Cafeteria 1	Cafeteria	ND
Harding	Adjacent Room 143-2	Corridor A1	1.4
Harding	Room 259 Fountain	Room 259	1.5
Harding	Room 257 Fountain	Room 257	2.1
Harding	Kitchen Dish Sink 2	Kitchen	1.5
Harding	Kitchen Dish Sink 1	Kitchen	ND
<b>Harding</b>	<b>Kitchen Hand Sink</b>	<b>Kitchen</b>	<b>74.8</b>
Harding	Adjacent Room 106-1	Hallway	3.3
Harding	Adjacent Room 106-1	Hallway	1.1
Harding	Girls Locker Room Fountain	Girls Locker Room	ND
Harding	Boys Locker Room Fountain	Boys Locker Room	1.9
Harding	Adjacent Art Room 2	Corridor C2	2.2
Harding	Adjacent Art Room 1	Corridor C2	6.4
Harding	Adjacent Room 211-2	Corridor A2	ND
Harding	Adjacent Room 235-2	Corridor C2	ND
Harding	Fountain Corridor A2	Corridor A2	1.6
Harding	Adjacent Room 211-1	Corridor C2	1.3
Harding	Adjacent Room 238-2	Corridor C2	ND
Harding	Adjacent Room 235-1	Corridor C2	2.6

School	Sample Name	Location	Results (ppb)
Harding	Adjacent Room 238-1	Corridor C2	1.2
Harding	Room 258 Fountain	Room 258	5.1
Harding	Adjacent Room 251	Corridor C2	ND
Harding	Room 255 Fountain	Room 255	1.5
Harding*	Room 137- Main Draw*	Room 137*	1.6*
Brearley	Cafeteria Fountain 4	Cafeteria	ND
Brearley	Cafeteria Fountain 3	Cafeteria	ND
Brearley	Cafeteria Fountain 2	Cafeteria	2.1

Brearley	Cafeteria Fountain 1	Cafeteria	1.6
Brearley	Kitchen Dish Sink	Kitchen	7.1
Brearley	Teacher Cafeteria 2	Teacher Cafeteria	1.4
Brearley	Teacher Cafeteria 1	Teacher Cafeteria	2.2
Brearley	Machine Room 1	Machine Room	1.2
Brearley	Machine Room 2	Machine Room	1.8
Brearley	Main Draw	Principles Office	1.4
Brearley	2 <sup>nd</sup> Floor 2	Corridor D2	1.8
Brearley	2 <sup>nd</sup> Floor 1	Corridor D2	1.9
Brearley	Fountain Adjacent Main Office 2	Corridor A1	ND
Brearley	Fountain Adjacent Boys Locker Room 1	Corridor C1	ND
Brearley	Fountain Girls Locker Room Foyer	Girls Locker Room	5.7
Brearley	Fountain Adjacent Boys Locker Room 2	Corridor C1	ND
Brearley	Drama Room Sink	Drama Room	ND
Brearley	Fountain Adjacent Main Office 1	Corridor A1	1.3
Brearley	Fountain Boys Locker Room Back	Boys Locker Room	ND
Brearley	Band Room Fountain	Band Room	ND
Brearley	Nurses Exam Sink	Nurses Exam Room	2.6
Brearley	Board Office Sink	Board Office	1.8
Brearley	Nurse Storage Sink	Nurse Storage Room	ND
Brearley	Server Room 2	Server Room	ND
Brearley	Boys Locker Room Foyer	Boys Locker Room	ND
Brearley	Trainer Foyer	Adjacent Trainers Room	ND
Brearley	Girls Locker Room Back	Girls Locker Room	ND
Brearley	Server Room 1	Server Room	ND
Brearley	Kitchen Cooking Sink	Kitchen	ND